



MARK	QTY.	NPS	DESCRIPTION	I.C. No.
1	950 mm	4"	PIPE STD A106-B	P000L0PCAB
2	245 mm	2"	PIPE STD A106-B	P000L0PCAB
3	1	4"x2"	REDUCER CONC BW STD A234-WPB	R10CLOFCCA
4	1	4"	CAP BW STD A234-WPB	C100L0FCCA
5	1	2"	FLANGE RF WN STD A105N 300LB	F1WRLBFCAA
6	13	3/4"	NIPPLE PBE 3" LG XXS A106-B	N101N3PCAB
7	3	3/4"	PLUG HEX HD THD A105N	D2H030FCAA
8	13	4"x3/4"	SOCKOLET A105N 3000LB	Q2S02KFCAA
9	12	3/4"	VALVE GLOBE SWxTHD CS 800LB	LCCN8CN
10	1	3/4"	VALVE GATE SWxTHD CS 800LB	GACN8CN
11	1	4"	PIPE SHOE PS1 NOTE 1	PS1
12	1		C75x9 x 102 LONG G40.21M GR.300W NOTE 6	N/A

NOTES:

1. TRIM PIPE SHOE (MARK No. 11) TO 150 mm LONG.
2. ALL PIPING MATERIALS WILL FOLLOW IMV PIPING LINE CLASSES.
3. DO NOT BACK WELD PLUGS.
4. TO PREVENT CONTAMINATION DURING SHIPPING AND STORAGE, ALL VALVES NOT PLUGGED AND OPEN PIPING SHALL BE PROTECTED WITH TEMPORARY COVERS.
5. USE FIELD SUPPORT STEEL FS1B IF REQUIRED.
6. CENTER TAG ON MANIFOLD FRONT.

0	ISSUED FOR CONSTRUCTION								
REV	REVISION	DATE	DRN	CHK	ENG	APP			
CLIENT	TITLE GLYCOL TRACING RETURN MANIFOLD TYPE 'C'								
PREPARED BY	SCALE N.T.S.	DWG. No. GT-004	PROJ.	REV. 0					