



PIPE SIZE	'A'	'B'	'C'	'D'	'E'	'H'	
						MAX.	MIN.
12"	360	240	215	172	180	270	155
14"	360	240	215	167	180	270	155
16"	385	265	240	169	180	270	155
18"	415	295	270	171	180	270	155
20"	465	345	320	184	180	270	155
24"	565	445	420	211	220	320	155

NOTES

1. ALL MATERIAL IS CARBON STEEL PLATE CSA G40.21-04 GR.300W - 12mm TK.
2. PIPING FABRICATOR TO TACK WELD SHOES AT INSTALLED HEIGHT.
3. FIELD CONSTRUCTOR OR MODULE FABRICATOR TO GRIND OFF TACK WELDS IF NECESSARY, ADJUST TO FINAL HEIGHT AND ANGLE WELD AS INDICATED.
4. MINIMUM INSTALLED HEIGHT 'H' IS 155. FOR HEIGHTS LESS THAN 155 USE PSS-PS33/PSS-PS34 SHOES.
5. FOR ALL NON CS PIPING (ALLOY, FRP, PLASTIC) A 3mm THK THERMOFAB LINER OR EQUAL MUST BE WRAPPED AROUND THE PIPE AT THE CLAMP CONTACT POINTS.

0	ISSUED FOR CONSTRUCTION									
REV	REVISION					DATE	DRN	CHK	ENG	APP
CLIENT		TITLE PIPE SUPPORT STANDARD CLAMPED EXTRA LONG VARIABLE HEIGHT PIPE SHOE NPS 12" TO NPS 24" PS36								
PREPARED BY		SCALE	DWG. No. PSS-PS36				PROJ.		REV.	
		N.T.S.	CLIENT DWG. No.						0	