



NOMINAL PIPE SIZE	A	M	C	D	G	H	K	P	W	MAX. ALLOW. VERT. LOAD (kN)
2"	L76 X 76 X 7.9	C200 X 21	60	101	22 ϕ	3/4" X 2 1/4"	203	10	210	6
3"	L76 X 76 X 7.9	C200 X 21	60	101	22 ϕ	3/4" X 2 1/4"	203	10	240	6
4"	L76 X 76 X 7.9	C250 X 37	75	152	22 ϕ	3/4" X 2 1/4"	254	10	265	24
6"	L76 X 76 X 7.9	C250 X 37	75	152	22 ϕ	3/4" X 2 1/4"	254	10	320	24

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETERS, U.N.O.
2. VESSEL FABRICATOR SHALL FURNISH VESSEL CLIP WELDED TO VESSEL RE-PAD. ALL OTHER MATERIALS FURNISHED BY SUPPORT FABRICATOR.
3. ALL CLIPS WELDED TO VESSEL SHALL BE SAME MATERIAL AS VESSEL. ALL OTHER MATERIALS SHALL BE CARBON STEEL CSA G40.21 GR.300W.
4. BOLTS ASTM A325 C/W NUT AND WASHER.
5. FOR TRUNNION PIPE SUPPORTS SEE DETAILS, DWG PSS-DCS03.
6. DIMENSIONS ARE FOR 50mm INSULATION. GREATER INS. THICKNESS MUST BE LOCALLY COPED AT SUPPORT.
7. INDICATE LENGTH ON ISOMETRIC (COMMENT).

0	ISSUED FOR CONSTRUCTION									
REV	REVISION					DATE	DRN	CHK	ENG	APP
CLIENT		TITLE PIPE SUPPORT STANDARDS 2" TO 6" VESSEL SUPPORT FOR BARE AND INSULATED PIPE VS2								
PREPARED BY		SCALE	DWG. No. PSS-VS02				PROJ.		REV.	
		N.T.S.	CLIENT DWG. No.						0	